



DUPLICATE

DELHI TEST HOUSE[®]

A-62/3, G.T. Karnal Road, Industrial Area, Opp. Hans Cinema, Azadpur, Delhi-110 033 (INDIA)

Phone : +91-11-47075555 (30 Lines) Fax : +91-11-47075550

e-mail : info@delhitesthouse.com



Issued to:
The Head Mistress
Delhi Heritage School
Main Kanjhawala Road, Opp Sec-22, Rohini
Delhi-110085

Sample Description: WATER



QR-0302

Report No : 26670230111GEN4639

Date : 18-01-2023

Date of Receipt : 11-01-2023

Party Ref No : NIL, & DT:- 11.01.2023

TEST REPORT

Sl.no	Tests	Test Values	Test Method	Requirement IS:10500-2012,AMD.NO-1,2,3&4
1.CHEMICAL TESTING (WATER)				
1	COLOUR, HAZEN UNITS	5.2	IS:3025(P-4):1983	5 Max. Acceptable Limit. 15 Max. Rejection Limit
2	ODOUR	Agreeable	IS:3025(P-5):2018	Agreeable
3	TASTE	Agreeable	IS:3025(P-7):1984	Agreeable
4	TURBIDITY, NTU	<1	IS:3025(P-10):1984	1 Max Acceptable Limit. 5 Max Rejection Limit.
5	pH	7.73	IS:3025(P-11):2022	6.5-8.5 No Relaxation Rejection Limit
6	TOTAL HARDNESS as CaCO ₃ , mg/l	88.2	IS:3025(P-21):2009	200 Max Acceptable Limit 600 Max Rejection Limit
7	IRON as Fe, mg/l	BLQ (LOQ = 0.01)	IS:3025(P-53):2003	1.0 Max. Acceptable Limit No Relaxation Rejection Limit
8	CHLORIDE as Cl, mg/l	70.0	IS:3025(P-32):1988	250 Max Acceptable Limit 1000 Max Rejection Limit
9	TOTAL DISSOLVED SOLIDS, mg/l	261	IS:3025(P-16):1984	500 Max. Acceptable Limit 2000 Max Rejection Limit
10	FLUORIDE as F, mg/l	0.31	IS:3025(P-60):2008	1.0 Max. Acceptable Limit 1.5 Max. Rejection Limit

2.BIOLOGICAL TESTING (WATER)

1	COLIFORM ORGANISMS/100 ml. at 37°C	ABSENT	IS:15185:2016	Absent
2	E. COLI/100 ml.	ABSENT	IS:15185:2016	Absent

Remarks:

THE SAMPLE CONFORMS TO THE IS:10500-2012 WITH RESPECT TO ABOVE TEST ONLY.

NOTE: 1. BLQ :- Below Limit of Quantification, 2. LOQ :- Limit of Quantification

Note 1.No deviation from the Standard Test Method / Specification is done unless specified or requested by the client. 2. While giving the conformity statement laboratory should consider Uncertainty Measurement into account 3. General terms and conditions are given on the back side of the report
MAN-SO-395570-KHU-682023011886 dos/doc 11-JAN-23-16 JAN-23-16 ULR-TG647123000001677F DT For report verification email to report_verify@delhitesthouse.com

M.C. GOEL

Rachna Joshi
Chief Metro Analyst
Authorised Signatory, Director

ISO - 9001 : 2015 CERTIFIED LABORATORY

Other Lab : Plot No. 50 & 65, Phase - IV, Sector-57, HSIDC Industrial Area, Behind Parnami Hospital, Kundli, Sonapat-131028 (Haryana)